4 analog inputs (4-20 mA)

- ► 16-bit analog converter
- Optically and electrically isolated
 - Each channel has an electrically isolated analog ground
 - Each channel is individually optically isolated
- ▶ Each channel has individually configurable digital filtering

General specifications

Inputs per module	4 (single–ended)	
Input type	Current, 4 – 20 mA	
Connector	Removable	
Connection type	Screw terminal	
Terminal wire size	14 – 22 AWG	
Test point	All connections	
Module size	1 controller bay	

Bus power required (5 VDC)	0.2 mA
Isolation rating	500 VDC
Operating temperature	
Horizontal installation ¹	0 - 50°C
Vertical installation ¹	0 - 45°C
Storage temperature	-25 − 85°C
Humidity	5 – 95% non-condensing
5100 equivalent part number	Н


^{1.} Refer to the applicable controller datasheet for proper mounting instructions.


Performance specifications


Parameter	Value
Input range	4 – 20 mADC
Input resolution	16-bit
Input resistance	
+Ain to –Ain	$10^{12}\Omega$
+Ain to ACOM	$10^{12}\Omega$
-Ain to ACOM	1.5 M Ω
Max input voltage	±32 VDC
Full range calibration error ^{1, 2}	0.013% of range
Offset calibration error at 0 V ^{1, 2}	0.013% of range
Linearity error (full range) ^{1, 2}	0.037% of range
Digital input filter size (settable)	1 - 255 samples
Digital input filter rate	5 msec

- 1. Errors are at 25°C.
- Errors are double across full ambient temperature range of 0 - 50°C.

Typical Application








	5100	5200
Minimum hardware revision	A	Α
Minimum firmware revision	1.01	1.01
Minimum operating system revision	4.04.12	5.06
Document number: 950-513107-0004		

Connections



I/O Terminations		
TB1-1	VS_OUT	
TB1-2	+Ain #1	
TB1-3	+Ain #2	
TB1-4	+Ain #3	
TB1-5	+Ain #4	
TB2-1	VS_RTN	
TB2-2	ACOM	
TB2-3	ACOM	
TB2-4	ACOM	
TB2-5	ACOM	

Notes

- 1. Shield grounds must be terminated on the controller side of the cable.
- 2. When an analog device is powered via an external power source, it may be necessary to tie the ground of this power source to the module's analog common (ACOM) to limit common mode voltages.
- 3. For register and programming information, refer to the appropriate controller Applications Guide.
- 4. The information and illustrations contained herein are the property of Control Technology Corporation and are subject to change without notice. Data based on VS = 24VDC @ 25°C unless otherwise noted. For additional information and/or updates visit www.ctc-control.com.
- 5. VS refers to the voltage supply of the controller.